



Test Report: HLG-240H-C1750

250W Single Output LED Power Supply

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test



E.M.C. Test

■ RELIABILITY TEST


ENVIRONMENT TEST

DESIGN VERIFY TEST


OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	CURRENT TOLERANCE	±5%	I/P: 230 VAC I/P: 115VAC O/P: FULL LOAD Ta: 25°C	1.753A / 230VAC @ CV MAX-2V 1.754A / 230VAC @ CV MIN 1.753A / 115VAC @ CV MAX-2V 1.754A / 115VAC @ CV MIN +0.23%
2	CONSTANT CURRENT REGION	CH1: 71V~ 143V	I/P: 230 VAC O/P: FULL LOAD Ta: 25°C	60V~ 142V / 230VAC
3	OPEN CIRCUIT VOLTAGE (max.)	146V	I/P: 230 VAC O/P: NO LOAD Ta: 25°C	143.5V
4	CURRENT ADJ. RANGE	CH1: 875mA~ 1750mA	I/P: 230 VAC I/P: 115VAC O/P: CV MIN & CV MAX-2V Ta: 25°C	646mA~ 1953mA / 230VAC @ CV MAX-2V 646mA~ 1949mA / 230VAC @ CV MIN 645mA~ 1954mA / 115VAC @ CV MAX-2V 646mA~ 1949mA / 115VAC @ CV MIN
5	CURRENT RIPPLE	5.0% max. @ rated current	I/P: 230 VAC O/P: FULL LOAD Ta: 25°C	1.45%
6	SET UP TIME(Max)	230VAC/500 ms 115VAC/1000ms	I/P: 230 VAC I/P: 115 VAC O/P: FULL LOAD Ta: 25°C	230VAC/ 218ms 115 VAC/ 312ms
<div style="display: flex; justify-content: space-around;"> <div style="width: 45%;"> <p>INPUT=230VAC/50HZ @ FULL LOAD</p> <p>CH1 : Output Voltage CH2: AC Input Voltage</p>  <p>5 May 2015 14:57:28</p> </div> <div style="width: 45%;"> <p>INPUT=115VAC/60HZ @ FULL LOAD</p> <p>CH1 : Output Voltage CH2 : AC Input Voltage</p>  <p>5 May 2015 14:59:32</p> </div> </div>				
7	DIMMING OPERATION (for B-Type)	<p>※3 in 1 dimming function</p> <p>※Output constant current level can be adjusted by applying one of the three methodologies between DIM+ and DIM-: 1 ~ 10VDC, or 10V PWM signal or resistance.</p> <p>※Direct connecting to LEDs is suggested. It is not suitable to be used with additional drivers.</p> <p>※Dimming source current from power supply: 100μ A (typ.)</p>		


◎ Applying additive 1 ~ 10VDC




"DO NOT connect "DIM- to -V"




◎ Applying additive 10V PWM signal (frequency range 100Hz ~ 3KHz):




"DO NOT connect "DIM- to -V"




◎ Applying additive resistance:



"DO NOT connect "DIM- to -V"



Note: In the case of turning the lighting fixture down to 0% brightness, please refer to the configuration as follow, or please contact MEAN WELL for other options.






Using a switch and relay can turn ON/OFF the lighting fixture.

I/P : 230VAC


O/P : DIMMING TEST




TA : 25°C

R	10K	20K	30K	40K	50K	60K	70K	80K	90K	100K	OPEN
O/P CURRENT	0.178A	0.354A	0.534A	0.712A	0.891A	1.071A	1.245A	1.422A	1.618A	1.752A	1.761A
%	10.17%	20.23%	30.51%	40.69%	50.91%	61.20%	71.14%	81.26%	92.46%	100.11%	100.63%
V	1V	2V	3V	4V	5V	6V	7V	8V	9V	10V	OPEN

		<table><tr><td>O/P CURRENT</td><td>0.178A</td><td>0.362A</td><td>0.547A</td><td>0.725A</td><td>0.888A</td><td>1.066A</td><td>1.244A</td><td>1.423A</td><td>1.592A</td><td>1.750A</td><td>1.749A</td></tr><tr><td>%</td><td>10.17%</td><td>20.69%</td><td>31.26%</td><td>41.43%</td><td>50.74%</td><td>60.91%</td><td>71.09%</td><td>81.31%</td><td>90.97%</td><td>100.00%</td><td>99.91%</td></tr><tr><td>PWM (100HZ)</td><td>10%</td><td>20%</td><td>30%</td><td>40%</td><td>50%</td><td>60%</td><td>70%</td><td>80%</td><td>90%</td><td>100%</td><td>OPEN</td></tr><tr><td>O/P CURRENT</td><td>0.177A</td><td>0.335A</td><td>0.528A</td><td>0.703A</td><td>0.879A</td><td>1.053A</td><td>1.227A</td><td>1.401A</td><td>1.575A</td><td>1.750A</td><td>1.751A</td></tr><tr><td>%</td><td>10.11%</td><td>19.15%</td><td>30.17%</td><td>40.17%</td><td>50.23%</td><td>60.17%</td><td>70.11%</td><td>80.06%</td><td>90.00%</td><td>100.00%</td><td>100.06%</td></tr></table>	O/P CURRENT	0.178A	0.362A	0.547A	0.725A	0.888A	1.066A	1.244A	1.423A	1.592A	1.750A	1.749A	%	10.17%	20.69%	31.26%	41.43%	50.74%	60.91%	71.09%	81.31%	90.97%	100.00%	99.91%	PWM (100HZ)	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%	OPEN	O/P CURRENT	0.177A	0.335A	0.528A	0.703A	0.879A	1.053A	1.227A	1.401A	1.575A	1.750A	1.751A	%	10.11%	19.15%	30.17%	40.17%	50.23%	60.17%	70.11%	80.06%	90.00%	100.00%	100.06%
O/P CURRENT	0.178A	0.362A	0.547A	0.725A	0.888A	1.066A	1.244A	1.423A	1.592A	1.750A	1.749A																																																			
%	10.17%	20.69%	31.26%	41.43%	50.74%	60.91%	71.09%	81.31%	90.97%	100.00%	99.91%																																																			
PWM (100HZ)	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%	OPEN																																																			
O/P CURRENT	0.177A	0.335A	0.528A	0.703A	0.879A	1.053A	1.227A	1.401A	1.575A	1.750A	1.751A																																																			
%	10.11%	19.15%	30.17%	40.17%	50.23%	60.17%	70.11%	80.06%	90.00%	100.00%	100.06%																																																			
TEST RESULT : OK																																																														
8	DIMMING OPERATION (for Dxx-Type by User definition)	<p>※Smart timer dimming function (for Dxx-Type by User definition)</p> <p>MEAN WELL Smart timer dimming primarily provides the adaptive proportion dimming profile for the output constant current level to perform up to 14 consecutive hours. 3 dimming profiles hereunder are defined accounting for the most frequently seen applications. If other options may be needed,please contact MEAN WELL for details.</p> <p>Ex : Ⓒ D01-Type: the profile recommended for residential lighting</p> <div></div> <p>Operating Time(HH:MM)</p> <p>Set up for D01-Type in Smart timer dimming software program:</p> <table><tr><td></td><td>T1</td><td>T2</td><td>T3</td><td>T4</td></tr><tr><td>TIME**</td><td>06:00</td><td>07:00</td><td>11:00</td><td>--</td></tr><tr><td>LEVEL**</td><td>100%</td><td>70%</td><td>50%</td><td>70%</td></tr></table> <p>Ex : Ⓒ D02-Type: the profile recommended for street lighting</p> <div></div> <p>Operating Time(HH:MM)</p> <p>Set up for D02-Type in Smart timer dimming software program:</p> <table><tr><td></td><td>T1</td><td>T2</td><td>T3</td><td>T4</td><td>T5</td></tr><tr><td>TIME**</td><td>01:00</td><td>03:00</td><td>8:00</td><td>11:00</td><td>--</td></tr><tr><td>LEVEL**</td><td>50%</td><td>80%</td><td>100%</td><td>60%</td><td>80%</td></tr></table> <p>Ex : Ⓒ D03-Type: the profile recommended for tunnel lighting</p> <div></div> <p>Operating Time(HH:MM)</p> <p>Set up for D03-Type in Smart timer dimming software program:</p> <table><tr><td></td><td>T1</td><td>T2</td><td>T3</td></tr><tr><td>TIME**</td><td>01:30</td><td>11:00</td><td>---</td></tr><tr><td>LEVEL**</td><td>70%</td><td>100%</td><td>70%</td></tr></table>		T1	T2	T3	T4	TIME**	06:00	07:00	11:00	--	LEVEL**	100%	70%	50%	70%		T1	T2	T3	T4	T5	TIME**	01:00	03:00	8:00	11:00	--	LEVEL**	50%	80%	100%	60%	80%		T1	T2	T3	TIME**	01:30	11:00	---	LEVEL**	70%	100%	70%															
	T1	T2	T3	T4																																																										
TIME**	06:00	07:00	11:00	--																																																										
LEVEL**	100%	70%	50%	70%																																																										
	T1	T2	T3	T4	T5																																																									
TIME**	01:00	03:00	8:00	11:00	--																																																									
LEVEL**	50%	80%	100%	60%	80%																																																									
	T1	T2	T3																																																											
TIME**	01:30	11:00	---																																																											
LEVEL**	70%	100%	70%																																																											
I/P : 230VAC O/P : DIMMING TEST TA : 25℃ TEST RESULT : OK																																																														

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																												
1	INPUT VOLTAGE RANGE	90VAC~305 VAC	I/P:TESTING O/P:FULL LOAD Ta:25℃	70V~305V																																												
			I/P: (1)LOW-LINE-3V=87 V HIGH-LINE+10V=315 V O/P:FULL/MIN LOAD (PLEASE CHECK DERATING CURVE) ON: 30 Sec . OFF: 30 Sec 10MIN (POWER ON/OFF NO DAMAGE) (2) I/P:230Vac ON: 0.5 Sec . OFF: 0.5 Sec 20MIN	(1).TEST:OK (2).TEST :OK																																												
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE	I/P: 110 VAC ~305VAC O/P:FULL~MIN LOAD Ta:25℃	OK																																												
3	INPUT CURRENT (TYP)	277VAC/ 1.1 A 230 VAC/ 1.3 A 115 VAC/ 2.5 A	I/P: 277VAC/230 VAC/115 VAC O/P:FULL LOAD Ta:25℃	I= 1.000A/277VAC I = 1.173A/230VAC I = 2.401A/115VAC																																												
4	POWER FACTOR(TYP)	0.95/230 VAC FULL LOAD 0.98/115 VAC FULL LOAD 0.92/277 VAC FULL LOAD	I/P: 230 VAC/115VAC/277VAC O/P:FULL LOAD Ta:25℃	PF=0.9825 /230V/100%LOAD PF=0.9961/115V/100%LOAD PF=0.9488 /277V/100%LOAD																																												
5	<div>P.F vs LOAD</div>  <table><caption>P.F vs LOAD Data</caption><thead><tr><th>Load (%)</th><th>230V P.F</th><th>115V P.F</th><th>277V P.F</th></tr></thead><tbody><tr><td>10%</td><td>0.58</td><td>0.90</td><td>0.40</td></tr><tr><td>20%</td><td>0.78</td><td>0.95</td><td>0.60</td></tr><tr><td>30%</td><td>0.88</td><td>0.98</td><td>0.75</td></tr><tr><td>40%</td><td>0.92</td><td>0.99</td><td>0.82</td></tr><tr><td>50%</td><td>0.95</td><td>1.00</td><td>0.88</td></tr><tr><td>60%</td><td>0.96</td><td>1.00</td><td>0.90</td></tr><tr><td>70%</td><td>0.97</td><td>1.00</td><td>0.92</td></tr><tr><td>80%</td><td>0.98</td><td>1.00</td><td>0.94</td></tr><tr><td>90%</td><td>0.98</td><td>1.00</td><td>0.95</td></tr><tr><td>100%</td><td>0.98</td><td>1.00</td><td>0.95</td></tr></tbody></table>				Load (%)	230V P.F	115V P.F	277V P.F	10%	0.58	0.90	0.40	20%	0.78	0.95	0.60	30%	0.88	0.98	0.75	40%	0.92	0.99	0.82	50%	0.95	1.00	0.88	60%	0.96	1.00	0.90	70%	0.97	1.00	0.92	80%	0.98	1.00	0.94	90%	0.98	1.00	0.95	100%	0.98	1.00	0.95
	Load (%)	230V P.F	115V P.F	277V P.F																																												
10%	0.58	0.90	0.40																																													
20%	0.78	0.95	0.60																																													
30%	0.88	0.98	0.75																																													
40%	0.92	0.99	0.82																																													
50%	0.95	1.00	0.88																																													
60%	0.96	1.00	0.90																																													
70%	0.97	1.00	0.92																																													
80%	0.98	1.00	0.94																																													
90%	0.98	1.00	0.95																																													
100%	0.98	1.00	0.95																																													
5	EFFICIENCY (TYP)	94 %	I/P: 230 VAC O/P:FULL LOAD Ta:25℃	94.2%																																												
	EFFICIENCY vs LOAD																																															

				
6	TOTAL HARMONIC DISTORTION	<p>Total harmonic distortion will be lower than 20% when output loading is 50% or higher at 230VAC / 115VAC</p> <p>Total harmonic distortion will be lower than 20% when output loading is 75% or higher at 277VAC</p>	<p>I/P : 230VAC I/P : 115VAC O/P : 50% LOAD Ta : 25°C</p> <p>I/P : 277VAC O/P : 75% LOAD Ta : 25°C</p>	<p>THD : 5.2732 % THD : 4.0143 %</p> <p>THD : 6.6690 %</p>
			<p>THD&LOAD</p> 	
7	INRUSH CURRENT (TYP)	<p>230 V/ 75A COLD START</p> <p>(twid=700us measured at 50% Ipeak) COLD START</p>	<p>I/P: 230 VAC O/P: FULL LOAD Ta: 25°C</p>	<p>I = 61.7 A/ 230VAC</p> <p>T50= 584 us</p>
			<p>INPUT=230VAC/50HZ @ FULL LOAD CH2 : AC Input Voltage CH4 : Input current (1V=1A)</p> 	

ROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	OVER VOLTAGE PROTECTION	V1: 150V~ 165V	I/P: 305VAC I/P: 230VAC I/P: 90VAC O/P: MIN LOAD Ta:25°C	157.93V/ 305VAC 156.72V/ 230VAC 156.70V/ 90VAC PROTECTION TYPE : Shut down and latch off o/p voltage, re-power on to recover
2	OVER TEMPERATURE PROTECTION	PROTECTION TYPE : Shut down o/p voltage, recovers automatically after temperature goes down	I/P: 305 VAC I/P: 90 VAC O/P: FULL LOAD	O.T.P. Active PROTECTION TYPE : Shut down o/p voltage, recovers automatically after temperature goes down
3	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P: 305VAC I/P: 90 VAC O/P: FULL LOAD Ta:25°C	NO DAMAGE PROTECTION TYPE : Constant current limiting, recovers automatically after fault condition is removed

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	P.F.C Transistor (D to S) or (C to E) Peak Voltage	Q1 Rated 600V/19A	I/P: High-Line +3V =308V AC ON/OFF VDS: O/P: (1) Full Load (2) Output Short (3) FULL LOAD CONTINUE I/P: Low-Line -3V = 107V AC ON/OFF VDS: O/P: (1) Full Load (2) Output Short (3) FULL LOAD CONTINUE Ta:25°C	VDS: (1) 501V (2) 466V (3) 506V VDS: (1) 514V (2) 466V (3) 512V
2	PWM Transistor (D to S) or (C to E) Peak Voltage	Q3 Rated 20A/600V	I/P: High-Line +3V =308V AC ON/OFF VDS: O/P: (1) Full Load (2) Output Short (3) FULL LOAD CONTINUE I/P: Low-Line -3V =107V AC ON/OFF VDS: O/P: (1) Full Load (2) Output Short (3) FULL LOAD CONTINUE Ta:25°C	VDS: (1) 535V (2) 490V (3) 442V VDS: (1) 470V (2) 465V (3) 456V

3	Diode Peak Voltage	<p>D102 Rated 10A/400V</p> <p>D103 Rated 10A/400V</p>	<p>I/P:High-Line +3V = 308 V AC ON/OFF VDS: O/P: (1)Full Load (2)Output Short (3)FULL LOAD CONTINUE</p> <p>VDS: (1)Full Load (2)Output Short (3)FULL LOAD CONTINUE Ta:25°C</p>	<p>D102: VDS: (1)316V (2)31V (3)314V</p> <p>D103: VDS: (1)323V (2)36.8V (3)319V</p>
4	Input Capacitor Voltage	<p>C5 Rated: 150u/450V SURGE POWER :495V</p>	<p>I/P:High-Line +3V =308 V O/P: (1)Full Load input on/off (2) Min load input on /Off (3)Full Load /Min load Change Ta:25°C</p>	<p>(1)444V (2)454V (3)446V</p>
5	Control IC Voltage Test	<p>PWM IC U70 Rated 8.85V~16V</p>	<p>I/P:High-Line +3V =308 V AC ON/OFF O/P(1)FULL LOAD (2) Output Short (3)O.L.P (4)O.V.P. (5)NO (LOW LINE) Ta:25°C</p>	<p>(1) 15.3V (2) 14.6V (3) 14.7V (4) 15.3V (5) 15.2V</p>

SAFETY & EMC TEST

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	WITHSTAND VOLTAGE	IEC60950-1 I/P-O/P: 3.75KVAC/min I/P-FG: 2 KVAC/min<4.5mA O/P-FG:1.5KVAC/min	I/P-O/P: 4.125 KVAC/min I/P-FG: 2.4 KVAC/min O/P-FG: 1.8 KVAC/min Ta:25°C	I/P-O/P:4.05 mA I/P-FG: 4.16mA O/P-FG:3.51 mA NO DAMAGE
2	ISOLATION RESISTANCE	I/P-O/P:500VDC>100MΩ I/P-FG: 500VDC>100MΩ O/P-FG:500VDC>100MΩ	I/P-O/P: 500 VDC I/P-FG: 500 VDC O/P-FG: 500 VDC Ta:25°C	I/P-O/P:15.5 GΩ I/P-FG: 7.4G Ω O/P-FG: 30G Ω NO DAMAGE
3	GROUNDING CONTINUITY	IEC60950-1 FG(PE) TO CHASSIS OR TRACE < 100 mΩ	40A / 2min Ta:25°C	30 mΩ
4	LEAKAGE CURRENT	IEC60950-1 < 0.75mA / 277VAC	I/P: 277 VAC O/P:Min LOAD Ta:25°C	L-FG:0.33 mA N-FG:0.33 mA


E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT
1	HARMONIC	EN61000-3-2 CLASS A CLASS C	I/P: 230VAC/50HZ O/P:FULL LOAD Ta:25°C	PASS
2	CONDUCTION	EN55015 CLASS B	I/P: 230 VAC (50HZ) O/P:FULL/50% LOAD Ta:25°C	PASS Test by certified Lab
3	RADIATION	EN55015 CLASS B	I/P: 230 VAC (50HZ) O/P:FULL LOAD Ta:25°C	PASS Test by certified Lab
4	E.S.D	EN61000-4-2 LIGHT INDUSTRY AIR:8KV / Contact:4KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A
5	E.F.T	EN61000-4-4 INDUSTRY INPUT: 2KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A
6	SURGE	IEC61000-4-5 INDUSTRY L-N :2KV L,N-PE:4KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A
7	Test by certified Lab & Test Report Prepare			

RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT																																																																																
1	TEMPERATURE RISE TEST	<div>MODEL : HLG-240H-C1400</div> <div>1. ROOM AMBIENT BURN-IN : 3 HRS</div> <div>I/P : 230VAC O/P : FULL LOAD Ta= 29.2 °C</div> <div>2. HIGH AMBIENT BURN-IN : 6 HRS</div> <div>I/P : 230VAC O/P : FULL LOAD Ta= 55.7 °C</div> <table><thead><tr><th>NO</th><th>Position</th><th>ROOM AMBIENT</th><th>HIGH AMBIENT</th></tr></thead><tbody><tr><td>1</td><td>BD1</td><td>71.7°C</td><td>94.1°C</td></tr><tr><td>2</td><td>C14</td><td>69.7°C</td><td>92.2°C</td></tr><tr><td>3</td><td>LF2</td><td>67.8°C</td><td>89.8°C</td></tr><tr><td>4</td><td>Q1</td><td>71.3°C</td><td>94.1°C</td></tr><tr><td>5</td><td>D3</td><td>713.0°C</td><td>93.9°C</td></tr><tr><td>6</td><td>L2</td><td>70.1°C</td><td>92.4°C</td></tr><tr><td>7</td><td>L1</td><td>71.9°C</td><td>94.1°C</td></tr><tr><td>8</td><td>D2</td><td>71.0°C</td><td>93.5°C</td></tr><tr><td>9</td><td>TSW1</td><td>68.6°C</td><td>90.9°C</td></tr><tr><td>10</td><td>Q3</td><td>70.1°C</td><td>92.4°C</td></tr><tr><td>11</td><td>C5</td><td>67.3°C</td><td>89.8°C</td></tr><tr><td>12</td><td>C35</td><td>70.0°C</td><td>92.6°C</td></tr><tr><td>13</td><td>C37</td><td>70.0°C</td><td>92.6°C</td></tr><tr><td>14</td><td>D102</td><td>72.2°C</td><td>94.4°C</td></tr><tr><td>15</td><td>T1</td><td>90.3°C</td><td>111.5°C</td></tr><tr><td>16</td><td>C201</td><td>70.9°C</td><td>93.2°C</td></tr><tr><td>17</td><td>C102</td><td>69.4°C</td><td>91.8°C</td></tr><tr><td>18</td><td>U1</td><td>69.3°C</td><td>91.6°C</td></tr><tr><td>19</td><td>U201</td><td>74.3°C</td><td>96.8°C</td></tr></tbody></table>			NO	Position	ROOM AMBIENT	HIGH AMBIENT	1	BD1	71.7°C	94.1°C	2	C14	69.7°C	92.2°C	3	LF2	67.8°C	89.8°C	4	Q1	71.3°C	94.1°C	5	D3	713.0°C	93.9°C	6	L2	70.1°C	92.4°C	7	L1	71.9°C	94.1°C	8	D2	71.0°C	93.5°C	9	TSW1	68.6°C	90.9°C	10	Q3	70.1°C	92.4°C	11	C5	67.3°C	89.8°C	12	C35	70.0°C	92.6°C	13	C37	70.0°C	92.6°C	14	D102	72.2°C	94.4°C	15	T1	90.3°C	111.5°C	16	C201	70.9°C	93.2°C	17	C102	69.4°C	91.8°C	18	U1	69.3°C	91.6°C	19	U201	74.3°C	96.8°C
NO	Position	ROOM AMBIENT	HIGH AMBIENT																																																																																	
1	BD1	71.7°C	94.1°C																																																																																	
2	C14	69.7°C	92.2°C																																																																																	
3	LF2	67.8°C	89.8°C																																																																																	
4	Q1	71.3°C	94.1°C																																																																																	
5	D3	713.0°C	93.9°C																																																																																	
6	L2	70.1°C	92.4°C																																																																																	
7	L1	71.9°C	94.1°C																																																																																	
8	D2	71.0°C	93.5°C																																																																																	
9	TSW1	68.6°C	90.9°C																																																																																	
10	Q3	70.1°C	92.4°C																																																																																	
11	C5	67.3°C	89.8°C																																																																																	
12	C35	70.0°C	92.6°C																																																																																	
13	C37	70.0°C	92.6°C																																																																																	
14	D102	72.2°C	94.4°C																																																																																	
15	T1	90.3°C	111.5°C																																																																																	
16	C201	70.9°C	93.2°C																																																																																	
17	C102	69.4°C	91.8°C																																																																																	
18	U1	69.3°C	91.6°C																																																																																	
19	U201	74.3°C	96.8°C																																																																																	
	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 305VAC/110VAC O/P : 100 % LOAD Ta= -40°C	TEST : OK																																																																																
	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 60 °C NO DAMAGE	I/P : 305 VAC O/P : FULL LOAD Ta= 60 °C HUMIDITY= 95 %R.H	TEST : OK																																																																																
	TEMPERATURE COEFFICIENT	± 0.03 %/°C (0-60°C)	I/P : 230 VAC O/P : FULL LOAD	± 0.022 %/°C (0-60°C)																																																																																
6	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature : -45°C~ +90°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 5 CYCLE 5. Input/Output condition : STATIC		OK																																																																																

7	THERMAL SHOCK TEST	1. Thermal shock Temperature : $-45^{\circ}\text{C} \sim +65^{\circ}\text{C}$ 2. Temperature change rate : $25^{\circ}\text{C} / \text{MIN}$ 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 10 CYCLE 5. Input/Output condition : 230VAC/Full Load AC ON/OFF TEST turn on 58sec ; turn off 2sec	OK
8	VIBRATION TEST	1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 10~500Hz (3) Sweep Time : 12min/sweep cycle (4) Acceleration : 5G (5) Test Time : 72min in each axis (X.Y.Z) (6) Ta : 25°C	TEST : OK
9	CAPACITOR LIFE CYCLE	HLG-240H-C1400 : SUPPOSE C102 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Ta= 25°C LIFE TIME (2) I/P : 230VAC O/P : FULL LOAD Ta= 60°C LIFE TIME (3) I/P : 230VAC O/P : 75% LOAD Ta= 60°C LIFE TIME (4) I/P : 230VAC O/P : 50% LOAD Ta= 60°C LIFE TIME	(1) 436254 HRS (2) 43683 HRS (3) 61824 HRS (4) 62561 HRS
10	MTBF	Conducted by Parts Stress Analysis Prediction 180K hrs min. MIL-HDBK-217F (25°C)	
11	DMTBF/Accelerated Life Test	Demonstration Mean Time Between Failure(Expected Life) : 62,000 hours @ Tcase 75°C 	

TEST RESULT	TESTER	REVIEW	APPROVAL
PASS	DANIEL GAO	SANFORD SU	VINCENT TSENG