



中国国家强制性产品认证证书

证书编号: 2015011002780468

委托人名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者(制造商)名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产企业名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园B栋

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置,内装式,恒流输出,
安全特低电压, ta: 40℃, 定温热保护: 110℃)

见附件: 100-240V~ 50/60Hz

产品标准和技术要求

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-
2012

上述产品符合强制性产品认证实施规则
CNCA-C10-01: 2014的要求, 特发此证。

发证日期: 2015年06月15日

有效期至: 2020年06月15日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1153000



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2015011002780468

NAME AND ADDRESS OF THE APPLICANT

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Industry Zone, Huangcun, Dongpu Town, Tianhe District, Guangzhou City, Guangdong Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Industry Zone, Huangcun, Dongpu Town, Tianhe District, Guangzhou City, Guangdong Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Mean Well (Guangzhou) Electronics Co., Ltd.
B Building, Yuean Industry Zone, Huangcun, Dongpu Town, Tianhe District, Guangzhou City, Guangdong Province, P.R.China

NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Built-in, Constant Current Mode, SELV, ta: 40°C, Temperature Declared Thermally Protected: 110°C)
See Appendix. 100-240V~ 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C10-01:2014).

Date of issue: Jun.15,2015 Date of expiry: Jun.15,2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1153000





中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2015011002780468

纸号: 1153000

序号	产品型号	参数
1	PLC-30-9	输出: Max. 9Vdc, 3.3A, Max. 30W, tc: 80°C
2	PLC-30-12	输出: Max. 12Vdc, 2.5A, Max. 30W, tc: 75°C
3	PLC-30-15	输出: Max. 15Vdc, 2.0A, Max. 30W, tc: 75°C
4	PLC-30-20	输出: Max. 20Vdc, 1.5A, Max. 30W, tc: 75°C
5	PLC-30-24	输出: Max. 24Vdc, 1.25A, Max. 30W, tc: 75°C
6	PLC-30-27	输出: Max. 27Vdc, 1.12A, Max. 30W, tc: 75°C
7	PLC-30-36	输出: Max. 36Vdc, 0.84A, Max. 30W, tc: 75°C
8	PLC-30-48	输出: Max. 48Vdc, 0.63A, Max. 30W, tc: 75°C
输入: 100-240V ~ 50/60Hz, ta: 40°C, SELV,  ,  , 内装式		

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

