



中国国家强制性产品认证证书

证书编号: 2015011002771532

委托人名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者(制造商)名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产企业名称、地址

明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园B栋

产品名称和系列、规格、型号

LED模块用交流电子控制装置(LED控制装置,内装式,恒压/恒流模式,安全特低电压,ta:40℃,tc:80℃,F标记,定温热保护:110℃)

PLC-100-48 输出: 48Vdc/2.0A Max.96W, PLC-100-12 输出: 12Vdc/5.0A Max.75W,
PLC-100-15 输出: 15Vdc/5.0A Max.75W, PLC-100-20 输出: 20Vdc/4.8A Max.96W,
PLC-100-24 输出: 24Vdc/4.0A Max.96W, PLC-100-27 输出: 27Vdc/3.55A
Max.96W, PLC-100-36 输出: 36Vdc/2.65A Max.96W; 100-240V~, 50/60Hz.

产品标准和技术要求

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

上述产品符合强制性产品认证实施规则
CNCA-C10-01:2014的要求,特发此证。

发证日期: 2015年05月11日

有效期至: 2020年05月11日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1101892



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2015011002771532

NAME AND ADDRESS OF THE APPLICANT

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

Mean Well (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME AND ADDRESS OF THE FACTORY

Mean Well (Guangzhou) Electronics Co., Ltd.
B Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District,
Guangzhou, China

NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Built-in,
Constant Voltage/Constant Current Mode, SELV, ta:40°C, tc:80°C, F
Mark, Temperature Declared Thermally Protected: 110°C)
PLC-100-48 Output: 48Vdc/2.0A Max.96W, PLC-100-12 Output: 12Vdc/5.0A
Max.75W, PLC-100-15 Output: 15Vdc/5.0A Max.75W, PLC-100-20 Output:
20Vdc/4.8A Max.96W, PLC-100-24 Output: 24Vdc/4.0A Max.96W, PLC-100-27
Output: 27Vdc/3.55A Max.96W, PLC-100-36 Output: 36Vdc/2.65A Max.96W; 100-
240V~, 50/60Hz.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB19510.14-2009, GB19510.1-2009, GB17743-2007, GB17625.1-2012

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C10-01:2014).

Date of issue: May.11,2015 Date of expiry: May.11,2020

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2015011002771532

纸号: 1101892

序号	产品型号	参数
1	PLC-100-48	输出: 48V $\overline{\text{—}}$, 2.0A (恒压恒流), 配套光源: Max.96W LED 模块
2	PLC-100-12	输出: 12V $\overline{\text{—}}$, 5.0A (恒压恒流), 配套光源: Max.75W LED 模块
3	PLC-100-15	输出: 15V $\overline{\text{—}}$, 5.0A (恒压恒流), 配套光源: Max.75W LED 模块
4	PLC-100-20	输出: 20V $\overline{\text{—}}$, 4.8A (恒压恒流), 配套光源: Max.96W LED 模块
5	PLC-100-24	输出: 24V $\overline{\text{—}}$, 4.0A (恒压恒流), 配套光源: Max.96W LED 模块
6	PLC-100-27	输出: 27V $\overline{\text{—}}$, 3.55A (恒压恒流), 配套光源: Max.96W LED 模块
7	PLC-100-36	输出: 36V $\overline{\text{—}}$, 2.65A (恒压恒流), 配套光源: Max.96W LED 模块

输入: 100-240V~, 50/60Hz, 1.4A, ta: 40°C, tc: 80°C, SELV, , , , 内装式

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

