



Test Report: LPF-90D-15

90W Single Output Switching Power Supply

■ DESIGN VERIFY TEST

Output Function Test

Input Function Test

Protection Function Test

Component Stress Test

■ SAFETY & E.M.C. TEST

Safety Test

E.M.C. Test

■ RELIABILITY TEST

ENVIRONMENT TEST

DESIGN VERIFY TEST

OUTPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	RIPPLE & NOISE	V1 : 150 mVp-p (Max)	I/P : 230VAC O/P : FULL LOAD Ta : 25°C	V1 : 17.2 mVp-p (Max)	P
2	CONSTANT CURRENT REGION	V1= 9V~15V	I/P : 230VAC O/P : CV MODE Ta : 25°C	O/P= 14V/ 5.073 A O/P= 9 V / 5.102 A	P
3	OUTPUT VOLTAGE TOLERANCE	V1 : 4 %~ -4 % (Max)	I/P : 100 VAC / 305 VAC O/P : FULL/ MIN LOAD Ta : 25°C	V1 : 0.6 %~ -0.6 %	P
4	LINE REGULATION	V1 : 0.5 %~ -0.5 % (Max)	I/P : 100 VAC ~ 305 VAC O/P : FULL LOAD Ta : 25°C	V1 : 0 %~ 0 %	P
5	LOAD REGULATION	V1 : 1.5 %~ -1.5 % (Max)	I/P : 230 VAC O/P : FULL ~MIN LOAD Ta : 25°C	V1 : 0.36 %~ 0.36 %	P
6	SET UP TIME	230VAC : 500 ms (Max) 115VAC : 1200 ms(Max)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 276 ms 115VAC/ 280 ms	P
7	RISE TIME	230VAC : 200 ms (Max) 115VAC : 200 ms (Max)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 19.634 ms 115VAC/ 16.738 ms	P
8	HOLD UP TIME	230VAC : 16 ms (TYP) 115VAC : 16 ms (TYP)	I/P : 230 VAC I/P : 115 VAC O/P : FULL LOAD Ta : 25°C	230VAC/ 88.776 ms 115VAC/ 38.652 ms	P
9	OVER/UNDERSHOOT TEST	< ±5%	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	TEST : <5 %	P
10	DYNAMIC LOAD	V1 : 1500 mVp-p	I/P : 230 VAC (1).O/P : FULL /Min LOAD 90%DUTY/ 1KHZ (2).O/P : FULL /Min LOAD 50%DUTY/ 120HZ Ta : 25°C	(1)211 mVp-p (2)593 mVp-p	P

11

DIMMER TEST

SPEC:

*Reference resistance value for output current adjustment (Typical)

Resistance value	10K	20K	30K	40K	50K	60K	70K	80K	90K	100K
Output current	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

*1 ~ 10V dimming function for output current adjustment (Typical)

Dimming value	1V	2V	3V	4V	5V	6V	7V	8V	9V	10V
Output current	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

*10V PWM signal for output current adjustment (Typical)

Duty value	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
Output current	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%

TEST RESULT: I/P : 230 VAC ;Ta : 25℃

1	Resistance value	10K	20K	30K	40K	50K	60K	70K	80K	90K	100K
	Output current	0.613A	1.113A	1.535A	2.039A	2.553A	3.067A	3.571A	4.073A	4.577A	5.079A
	%	12.26%	22.26%	30.70%	40.78%	51.06%	61.34%	71.42%	81.46%	91.54%	101.58%
2	Dimming value	1V	2V	3V	4V	5V	6V	7V	8V	9V	10V
	Output current	0.584A	1.065A	1.472A	1.971A	2.442A	2.986A	3.426A	3.947A	4.455A	4.933A
	%	11.68%	21.30%	29.44%	39.42%	48.84%	59.72%	68.52%	78.94%	89.10%	98.66%
3	Duty value	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
	Output current	0.586A	1.086A	1.499A	2.002A	2.509A	3.043A	3.529A	4.033A	4.532A	5.026A
	%	11.72%	21.72%	29.98%	40.04%	50.18%	60.86%	70.58%	80.66%	90.64%	100.52%

P

P

INPUT FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	INPUT VOLTAGE RANGE	100VAC~305 VAC	I/P : TESTING O/P : FULL LOAD Ta : 25°C	76.04V~305V	P
			I/P : LOW-LINE-3V=97 V HIGH-LINE=305 V O/P : FULL/MIN LOAD ON : 30 Sec . OFF : 30 Sec 10MIN (AC POWER ON/OFF NO DAMAGE)	TEST : OK	
2	INPUT FREQUENCY RANGE	47HZ ~63 HZ NO DAMAGE OSC	I/P : 100 VAC ~ 305 VAC O/P : FULL ~MIN LOAD Ta : 25°C	TEST : OK	P
3	POWER FACTOR	0.96 / 230 VAC(TYP) 0.97 / 115 VAC(TYP) 0.95 / 277 VAC(TYP)	I/P : 230 VAC I/P : 115 VAC I/P : 277 VAC O/P : FULL LOAD Ta : 25°C	PF= 0.9874 / 100% PF= 0.9981 / 100% PF= 0.9795 / 100%	P
4	EFFICIENCY	89% (TYP)	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	89.421 %	P
5	INPUT CURRENT	230V/ 0.5 A (TYP) 115V/ 0.95 A (TYP) 277V/ 0.4 A (TYP)	I/P : 230 VAC I/P : 115 VAC I/P : 277 VAC O/P : FULL LOAD Ta : 25°C	I = 0.3621 A/ 230 VAC I = 0.7295 A/ 115 VAC I = 0.3065 A/ 277 VAC	P
6	INRUSH CURRENT	230V/ 55 A (TYP) COLD START	I/P : 230 VAC O/P : FULL LOAD Ta : 25°C	I = 59.898 A/ 230 VAC	P
7	LEAKAGE CURRENT	< 0.75 mA / 277 VAC	I/P : 277 VAC O/P : Min LOAD Ta : 25°C	L-CASE : 0.01 mA N-CASE : 0.01 mA	P

PROTECTION FUNCTION TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	OVER LOAD PROTECTION	95 % ~ 108 %	I/P : 230 VAC I/P : 115 VAC O/P : TESTING Ta : 25°C	102.12%/ 230 VAC 102.18%/ 115 VAC Constant Current Limiting ,recovers automatically after fault condition is removed.	P
2	OVER VOLTAGE PROTECTION	CH1 : 18 V ~ 21 V	I/P : 230 VAC I/P : 115 VAC O/P : MIN LOAD Ta : 25°C	19.2V/ 230 VAC 19.2V/ 115 VAC Shut down o/p voltage, re-power on to recover	P
3	OVER TEMPERATURE PROTECTION	SPEC : RTH2 : 90±10°C O.T.P. NO DAMAGE	I/P : 230 VAC O/P : FULL LOAD	O.T.P. Active Shut down o/p voltage, re-power on to recover	P
4	SHORT PROTECTION	SHORT EVERY OUTPUT 1 HOUR NO DAMAGE	I/P : 305 VAC O/P : FULL LOAD Ta : 25°C	NO DAMAGE Hiccup mode, recovers automatically after fault condition is removed.	P

COMPONENT STRESS TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	Power Transistor (D to S) or (C to E) Peak Voltage	Q 2 Rated : TK10A60D 10A/600V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on (2) Output Short (3)Full load continue Ta : 25°C	(1) 432 V (2) 436 V (3) 432 V	P
2	Diode Peak Voltage	Q101 Rated : IRFB3607PBF 80A/75V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on (2)Output Short (3)Full load continue Ta : 25°C	(1) 72 V (2) 54.4 V (3) 69.6 V	P
3	Input Capacitor Voltage	C5 Rated : 82u/450V 105°C	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 449 V (2) 440 V (3) 440 V	P
4	Control IC Voltage Test	U 1 Rated : TEA1752T 17V~30V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on /Off (2) Min load Turn on /Off (3)Full Load /Min load Change Ta : 25°C	(1) 22.2 V (2) 21.6 V (3) 21.6 V	P
5	Power Transistor (D to S) or (C to E) Peak Voltage	Q1 Rated : 2SK3677-01MR 12A/700V	I/P : High-Line +3V = 308 V O/P : (1)Full Load Turn on (2) Output Short (3)Full load continue Ta : 25°C	(1) 632 V (2) 536 V (3) 624 V	P

■ SAFETY & E.M.C. TEST

SAFETY TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	WITHSTAND VOLTAGE	I/P-O/P : 3.75 KVAC/min	I/P-O/P : 4 KVAC/min Ta : 25°C	I/P-O/P : 3.90 mA NO DAMAGE	P
2	ISOLATION RESISTANCE	I/P-O/P : 500VDC>100MΩ	I/P-O/P : 500 VDC Ta : 25°C/70%RH	I/P-O/P : 30 GΩ NO DAMAGE	P

E.M.C TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT
1	HARMONIC	EN61000-3-2 CLASS C	I/P:230VAC/240VAC/220VAC50HZ O/P:100%,75%,60%LOAD CLASS C ≥60% Ta:25°C	PASS	P
2	CONDUCTION	EN55022 CLASS B	I/P: 230 VAC (50HZ)/115V[60HZ] O/P:FULL/60% LOAD Ta:25°C	PASS Test by certified Lab	P
3	RADIATION	EN55022 CLASS B	I/P: 230 VAC (50HZ)/115V[60HZ] O/P:FULL LOAD Ta:25°C	PASS Test by certified Lab	P
4	E.S.D	AIR:8KV / Contact:6KV INDUSTRY	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	P
5	E.F.T	EN61000-4-4 INDUSTRY INPUT: 2KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	P
6	SURGE	IEC61000-4-5 INDUSTRY L-N :2KV	I/P: 230 VAC/50HZ O/P:FULL LOAD Ta:25°C	CRITERIA A	P
7	Test by certified Lab & Test Report Prepare				

RELIABILITY TEST

ENVIRONMENT TEST

NO	TEST ITEM	SPECIFICATION	TEST CONDITION	RESULT	VERDICT																																																																																																																								
1	TEMPERATURE RISE TEST	MODEL : LPF-90-15 1. ROOM AMBIENT BURN-IN : 1 HRS I/P : 230VAC O/P : 95% LOAD Ta=37.5 °C 2. HIGH AMBIENT BURN-IN : 2 HRS I/P : 230VAC O/P : 95% LOAD Ta=51.6℃ <table><thead><tr><th>NO</th><th>Position</th><th>P/N</th><th>ROOM AMBIENT Ta=37.5℃</th><th>HIGH AMBIENT Ta= 51.6℃</th></tr></thead><tbody><tr><td>1</td><td>LF1</td><td>TR-990</td><td>57.1℃</td><td>70.1℃</td></tr><tr><td>2</td><td>LF2</td><td>TR-910B</td><td>63.5℃</td><td>76.5℃</td></tr><tr><td>3</td><td>L1</td><td>TR-995</td><td>63.7℃</td><td>76.6℃</td></tr><tr><td>4</td><td>C11</td><td>564/450V</td><td>65.3℃</td><td>78.4℃</td></tr><tr><td>5</td><td>D6</td><td>MUR460</td><td>67.1℃</td><td>79.8℃</td></tr><tr><td>6</td><td>Q2</td><td>TK10A60D</td><td>68.2℃</td><td>81.4℃</td></tr><tr><td>7</td><td>L3</td><td>TF-2157</td><td>64.1℃</td><td>77.0℃</td></tr><tr><td>8</td><td>Q1</td><td>2SK3677</td><td>71.5℃</td><td>84.9℃</td></tr><tr><td>9</td><td>C5</td><td>82u/450V KXG</td><td>68.8℃</td><td>81.6℃</td></tr><tr><td>10</td><td>D12</td><td>GP20K</td><td>72.7℃</td><td>86.0℃</td></tr><tr><td>11</td><td>T1</td><td>TF-2159</td><td>72.8℃</td><td>85.8℃</td></tr><tr><td>12</td><td>U1</td><td>TEA1752T</td><td>67.9℃</td><td>80.8℃</td></tr><tr><td>13</td><td>C22</td><td>33u/50V YXM</td><td>62.8℃</td><td>76.3℃</td></tr><tr><td>14</td><td>C18</td><td>33u/50V YXM</td><td>61.3℃</td><td>78.4℃</td></tr><tr><td>15</td><td>C152</td><td>47uF/50V YXM</td><td>69.5℃</td><td>82.3℃</td></tr><tr><td>16</td><td>C153</td><td>47uF/50V YXM</td><td>69.5℃</td><td>82.9℃</td></tr><tr><td>17</td><td>Q101</td><td>IRFB3607PBF</td><td>68.5℃</td><td>82.3℃</td></tr><tr><td>18</td><td>C106</td><td>1500u/25V ZLH</td><td>66.7℃</td><td>80.2℃</td></tr><tr><td>19</td><td>C107</td><td>1500u/25V ZLH</td><td>64.8℃</td><td>77.9℃</td></tr><tr><td>20</td><td>L100</td><td>TR-884</td><td>64.3℃</td><td>77.8℃</td></tr><tr><td>21</td><td>C111</td><td>220u/35V ZLH</td><td>61.1℃</td><td>74.6℃</td></tr><tr><td>22</td><td>U101</td><td>TEA1791T</td><td>72.8℃</td><td>85.9℃</td></tr><tr><td>23</td><td>RTH2</td><td>100KΩ 3Φ 1%</td><td>64.7℃</td><td>77.4℃</td></tr></tbody></table>			NO	Position	P/N	ROOM AMBIENT Ta=37.5℃	HIGH AMBIENT Ta= 51.6℃	1	LF1	TR-990	57.1℃	70.1℃	2	LF2	TR-910B	63.5℃	76.5℃	3	L1	TR-995	63.7℃	76.6℃	4	C11	564/450V	65.3℃	78.4℃	5	D6	MUR460	67.1℃	79.8℃	6	Q2	TK10A60D	68.2℃	81.4℃	7	L3	TF-2157	64.1℃	77.0℃	8	Q1	2SK3677	71.5℃	84.9℃	9	C5	82u/450V KXG	68.8℃	81.6℃	10	D12	GP20K	72.7℃	86.0℃	11	T1	TF-2159	72.8℃	85.8℃	12	U1	TEA1752T	67.9℃	80.8℃	13	C22	33u/50V YXM	62.8℃	76.3℃	14	C18	33u/50V YXM	61.3℃	78.4℃	15	C152	47uF/50V YXM	69.5℃	82.3℃	16	C153	47uF/50V YXM	69.5℃	82.9℃	17	Q101	IRFB3607PBF	68.5℃	82.3℃	18	C106	1500u/25V ZLH	66.7℃	80.2℃	19	C107	1500u/25V ZLH	64.8℃	77.9℃	20	L100	TR-884	64.3℃	77.8℃	21	C111	220u/35V ZLH	61.1℃	74.6℃	22	U101	TEA1791T	72.8℃	85.9℃	23	RTH2	100KΩ 3Φ 1%	64.7℃	77.4℃	P
NO	Position	P/N	ROOM AMBIENT Ta=37.5℃	HIGH AMBIENT Ta= 51.6℃																																																																																																																									
1	LF1	TR-990	57.1℃	70.1℃																																																																																																																									
2	LF2	TR-910B	63.5℃	76.5℃																																																																																																																									
3	L1	TR-995	63.7℃	76.6℃																																																																																																																									
4	C11	564/450V	65.3℃	78.4℃																																																																																																																									
5	D6	MUR460	67.1℃	79.8℃																																																																																																																									
6	Q2	TK10A60D	68.2℃	81.4℃																																																																																																																									
7	L3	TF-2157	64.1℃	77.0℃																																																																																																																									
8	Q1	2SK3677	71.5℃	84.9℃																																																																																																																									
9	C5	82u/450V KXG	68.8℃	81.6℃																																																																																																																									
10	D12	GP20K	72.7℃	86.0℃																																																																																																																									
11	T1	TF-2159	72.8℃	85.8℃																																																																																																																									
12	U1	TEA1752T	67.9℃	80.8℃																																																																																																																									
13	C22	33u/50V YXM	62.8℃	76.3℃																																																																																																																									
14	C18	33u/50V YXM	61.3℃	78.4℃																																																																																																																									
15	C152	47uF/50V YXM	69.5℃	82.3℃																																																																																																																									
16	C153	47uF/50V YXM	69.5℃	82.9℃																																																																																																																									
17	Q101	IRFB3607PBF	68.5℃	82.3℃																																																																																																																									
18	C106	1500u/25V ZLH	66.7℃	80.2℃																																																																																																																									
19	C107	1500u/25V ZLH	64.8℃	77.9℃																																																																																																																									
20	L100	TR-884	64.3℃	77.8℃																																																																																																																									
21	C111	220u/35V ZLH	61.1℃	74.6℃																																																																																																																									
22	U101	TEA1791T	72.8℃	85.9℃																																																																																																																									
23	RTH2	100KΩ 3Φ 1%	64.7℃	77.4℃																																																																																																																									
2	LOW TEMPERATURE TURN ON TEST	TURN ON AFTER 2 HOUR	I/P : 305VAC/100VAC O/P : 95 % LOAD Ta= -40 °C / -25℃	TEST : OK	P																																																																																																																								
3	HIGH HUMIDITY HIGH TEMPERATURE HIGH VOLTAGE TURN ON TEST	AFTER 12 HOURS IN CHAMBER ON CONTROL 50 °C NO DAMAGE	I/P : 305 VAC O/P : 95% LOAD Ta= 50 °C HUMIDITY= 95 %R.H	TEST : OK	P																																																																																																																								
4	TEMPERATURE COEFFICIENT	± 0.03 %(0~50℃)	I/P : 230 VAC O/P : 95% LOAD	± 0.01%(0~50℃)	P																																																																																																																								
5	STORAGE TEMPERATURE TEST	1. Thermal shock Temperature : -45℃~ +90℃ 2. Temperature change rate : 25℃ / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 5 CYCLE 5. Input/Output condition : STATIC		OK	P																																																																																																																								

6	THERMAL SHOCK TEST	1. Thermal shock Temperature : -45°C ~ +55°C 2. Temperature change rate : 25°C / MIN 3. Dwell time low and high temperature : 30 MIN/EACH 4. Total test cycle : 10 CYCLE 5. Input/Output condition : 230VAC/Full Load AC ON/OFF TEST turn on 58sec ; turn off 2sec	OK	P
7	VIBRATION TEST	1 Carton & 1 Set (1) Waveform : Sine Wave (2) Frequency : 10~500Hz (3) Sweep Time : 12min/sweep cycle (4) Acceleration : 5G (5) Test Time : 72min in each axis (X.Y.Z) (6) Ta : 25°C	TEST : OK	P
8	CAPACITOR LIFE CYCLE	SUPPOSE C106 IS THE MOST CRITICAL COMPONENT (1) I/P : 230VAC O/P : FULL LOAD Ta=25 °C LIFE TIME (2) I/P : 230VAC O/P : FULL LOAD Ta=50 °C LIFE TIME (3) I/P : 230VAC O/P : 75% LOAD Ta= 50 °C LIFE TIME (4) I/P : 230VAC O/P : 50% LOAD Ta= 50 °C LIFE TIME	(1) 375402 HRS (2) 69153 HRS (3) 96459 HRS (4) 133644 HRS	P
9	MTBF	MIL-HDBK-217F NOTICES2 PARTS COUNT TOTAL FAILURE RATE : 267.2 KHRS		P
10	DMTBF/Accelerated Life Test	Demonstration Mean Time Between Failure(Expected Life) : 50,000 hours @ Tcase 70°C		P

DATE	SAMPLE	TEST RESULT	TESTER	APPROVAL
2011/5/13	RD SAMPLE	PASS	SANFORD SU	VINCENT TSENG
2011/5/25	PRODUCT SAMPLE	PASS	SANFORD SU	VINCENT TSENG

2009/08/04 A50-F023