Ref. Certificate No.
NL-37489

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	Independent controlgears
Name and address of the Applicant Nom et adresse du demandeur	Mean Well Enterprises Co., Ltd. No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248 Taiwan
Name and address of the manufacturer Nom et adresse du fabricant	Mean Well Enterprises Co., Ltd. No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248 Taiwan
Name and address of the factory Nom et adresse de l'usine	Mean Well (Guangzhou) Electronics Co., Ltd. 2F, A Building, Yuean Industrial Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, Guangdong China
Rating and principal characteristics Valeurs nominales et caractéristiques principales	Class I, ta: 50 °C, tc: 90 °C, λ: 0,95, constant current independent controlgear, Inherently short-circuit proof, 110 °C thermal protection, MM mark; IP65 for models HLG-240H-CXY (X=700, 1050, 1400, 1750, 2100, Y=A, AB, AD2) IP67 for models l HLG-240H-CXY (X=700, 1050, 1400, 1750, 2100, Y= blank, B, D, D2) (Details refer to general product information of test report)
Trademark (if any) Marque de fabrique (si elle existe)	MW MEAN WELL
Type of manufacturer's Testing Laboratories used Type de programme de laboratoire d'essais constructeur	
Model / Type Ref. Réf. de type	HLG-240H-CXY (X=700, 1050, 1400, 1750, 2100, Y=blank, A, B, AB, D, D2, AD2)
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)	
A sample of product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et été considéré conforme à la CEI	61347-1(ed.2);am1;am2 61347-2-13(ed.2)
National differences / Comments Les différences nationales / Commentaires	EU Group Differences, AU, NZ
As shown in the test report Ref. No. which forms part of this certificate Comme indiqué dans le rapport d'essais numéro de référence qui constitue partie de ce certificat	4323724.50

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

DEKRA

Date: 2015-08-28

Signature: Rosa Zhou

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

Additional factory

Mean Well Enterprises Co., Ltd.

No.28, Wuquan 3 rd, Wugu Dist, New Taipei City 248

Taiwan

Suzhou Mean Well Technology Co., Ltd.

No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town, Xiang-cheng Dist, Suzhou, 215152 Jiangsu

China

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA

Date: 2015-08-28

Signature: Rosa Zhou